GULBARGA ELECTRICITY SUPPLY COMPANY LIMITED

(Undertaken by Government of Karnataka)

Registered Office, GESCOM, Corporate Office, Main Road, Kalaburagi-585102

Office No: 08392 255841

Fax No: 08392 257520

CIN: U4010KA2002SGC030436





Executive Engineer Elecl., O&M Rural Division, GESCOM, Ballari.

NO:-EEE/O&M/RD/BLY/AEE (0)/F-19/22-23/6339-45 Date: 23 NOV 2022

Proceeding of the HT Consumers Greviance meeting held on 14.11.2022 at

11:00 A.M in O&M Rural Division Office GESCOM Ballari.

Meeting Conveyed by: The Executive Engineer Elecl.,

O&M Rural Division, GESCOM, Ballari.

Meeting Present

: As per Annexure (Enclosed)

All the outset, The Executive Engineer Elecl., O&M Rural Division, GESCOM, Ballari, welcomed all the HT Consumers present and meeting started at 11:00 A.M and discussed about the HT consumers greviance.

2 Potoile		Remarks
Garudadhri Developers, Malapura.	Low voltage since last 3 months.	The installation is 17KMs away from the 110KV Thoranagal MUSS and once in a while voltage issues are observed specially during IP Set Peak seasons. However 110KV Anthapura sub station proposed was approved and work to be taken up by KPTCL. Meanwhile all necessary actions from concerned Sub Division AEE and SO will be taken to resolve the issues.
DRDO, Kodal Village.	Frequent power suppy interruption	As the existing 33KV line is tapped from 33KV Thoranagal – Vittlapura line, informed the official to construct exclusive 33KV or110KV line from 110KV KIADB sub station under self execution based on load requirement. Due to monsoon there were interruptions in 33KV Thoranagal – Vittlapura line, there are no interruptions since last month.
Sudhakar polymers Pvt. Ltd,.	Shifiting of HT line due to frequent power suppy interruption	Estimates prepared for the shifting of 11KV line and the work will be taken up shortly.

Yours faithfully,

Executive Engineer Elecl., O&M Rural Division, GESCOM, Ballari.

Copy submitted for kind information to:

- 1. The Chief Engineer(Ele), O&M Zone, GESCOM, Ballari.
- 2. The Superintending Engineer (Ele) O&M Circle, GESCOM, Ballari
- 3. The Executive Engineer Elecl., Regulatory Affairs, Corporate office, GESCOM, Kalaburgi.

Copy to:

- 1. The Asst. Executive Engineer(Ele), RT Division, KPTCl, Ballari.
- 2. The Asst. Executive Engineer(Ele), O&M Rural Sub Division, GESCOM, Ballari, Sandur, Siruguppa.
- 3. AEEE (O/AO/OC/MF.