

GULBARGA ELECTRICITY SUPPLY COMPANY LIMITED

NO.SEE/DCA/AO/AAO/JPA/2021-22/ 5241-53

Encl:-

☎:(08392) 274086

Fax: (08392) 274085

E-Mail:seeballari1@gmail.com

dcably.gescom@gmail.com



Office of the
Superintending Engineer (E),
O&M Circle, GESCOM,
Ballari.

Date:- 30 DEC 2021

Proceedings of the EHT/HT Consumer Interaction Meeting of O&M Divisions, held on 29.12.2021 at 11:00A.M at Division Office Hosapete.

Meeting Conveyed By: Superintending Engineer (E),
O&M Circle, Ballari.

Members Present : As per Annexure (Enclosed)

At the Outset, the Superintending Engineer (E), O&M Circle, GESCOM Ballari welcomed all the officers present and consumers meeting started at 11:00AM, and discussed about following issues:

- 1) Manjuntha Rice Mill, Hampi road Hosapete, consumer Mobile No: 9844094294 bearing the R.R. No:HT-56 as compliant about the interruption of F-8 MPP Nagar Feeder .
And also request for Discount energy saving.

The reason of interruption is due to long length of line and existing 8 RR Nos of HT consumers Hence request to bifurcate the load on existing feeder.

Action Plan: The Estimate is sanctioned with Work order UDA-4301 which is under tendering process and discussed about the discount energy saving to provide the consumer for the period of 6 months .

- 2) Shubalab Industries, Consumer Mobile No: 9448425326 bearing the R.R.No:VDHT-76 as compliant about the interruption of F-8 Gadiganoor NJY Feeder.
The reason is length of line about 35 KMs with connected 3 No's of HT and 15 No's of 40 HP consumers.

Action Plan: New link line proposed from 110/11 KV Sankalapura estimate cost about 45 lakhs and submitted for technical sanction to SE Office.


- 3) Sai Industries, Sudhakar Consumer Mobile No: 9448285704 M.M.Halli request to bifurcate the load.

Action Plan: From 66/11KV MUSS Venkatapura Station the new bifurcated line will be commissioned on from Jan 1st 2022 to reduce the load and statement by AEE RSD to avoid the interruption simultaneously the interruption will be minimised.

Note: General Issue stated by consumers' of Hosapete to upgrade the existing station of 33/11KV Challuvadikere to 110/11 KV KPTCL Sub-station for future industrial Development and also to provide Uninterrupted power for a newly formed Vijayanagara District in this regard GESCOM submitted DPR to KPTCL.

Meeting is concluded with vote of thanks to all the officers and HT/EHT consumers who attended the meeting.

Yours faithfully,


Superintending Engineer (Ele),
O&M Circle, GESCOM,
Ballari

Copy with compliments to:

1. The Chief Engineer (Ele), Operation, Corporate Office GESCOM Kalaburagi for kind information. ✓
2. The Chief Engineer (Ele), O & M Zone GESCOM Ballari for kind information. ✓

Copy for information to:

3. SPS to MD to place the subject before Hon'ble Managing Director GESCOM. ✓
4. SPS to DT to place the subject before Hon'ble Director of Technical GESCOM. ✓
5. All the Executive Engineer (Ele), O & M Urban/Rural and C&M, GESCOM Ballari. ✓
6. The Executive Engineer (Ele), TL & SS, KPTCL, Allipur Station, Ballari. ✓
7. All the Assistant Executive Engineer (Ele), O & M Rural Sub-Division, GESCOM Ballari/Siruguppa/Sandur/Ballari Urban Sub-division 1&2.
8. Copy to DCA/EE(O)/AO/AAO/JPA/OC/MF.