

GULBARGA ELECTRICITY SUPPLY COMPANY LIMITED

NO.SEE/DCA/AO/AAO/SAR/2021-22/ 5696-5712

Encl: -

☎:(08392) 274086

Fax: (08392) 274085

E-Mail:seeballari1@gmail.com

dcably.gescom@gmail.com



Office of the
Superintending Engineer (Ele),
O&M Circle, GESCOM,
Ballari.

Date:- 24 JAN 2022

Proceedings Of HT&EHT Consumer interaction meeting held on 21.01.2022. at hospete Under the Chairmanship of the Superintending Engineer (Ele), O & M Circle Gescom Ballari.

At the outset the Superintending Engineer (Ele), O & M Circle Gescom Ballari welcomed the all the officers and HT&EHT Consumer to the meeting

Complaint raised by consumers in the previous HT&EHT consumer meeting which was held on 29.12.2021 compliance report explained to the consumer as stated below;

Previous Complaints No: - 1 Name of the Consumer Sri. Manjunath Rice Mill Hampi Road Hospete Ph.No 9844094294 RR.No HT-56

Power interruption of F-8 MPP Nagar Feeder and also requested for Discounted Energy Rated Scheme.

The reason of interruption is due to long length of line and existing 8 RR No of HT consumer Hence request to bifurcate the load on existing feeder.

Action plan: The Estimate is sanctioned with work order UDA -4301 which is under tendering process in respected of Discounted Energy Rated Scheme this scheme is extended up to 31.03.2022

Previous Complaints No :- 2 Name Of The Consumer Shubalab Industries, RR.No VDHT-76 Ph.No :-9448425326

Power interruption of F-8 Gadiganoor NJY Feeder,

The reason is lengthy of line about 35 KMs with connected 3 Nos of HT and 15 No's of 40 Hp LT consumers.

Action plan: To attend the above complaint SEE O&M Circle Ballari has directed in the previous meeting to take needful action. Hence the concerned AEE O & M sub -Division RSD has submitted the link line estimate vide estimate No: 201521 and the Estimate cost Rs.43,83,724/-shortly this proposed link line is submitted to SE on 21.01.2022 personally, after technical sanction tender will be called to take further action.

Cntnd to 2

: 2 :

Previous Complaints No :- 3 Name Of The Consumer sai Industries,Sudhakar Ph.No :-
9448285704 M.M Halli

Requested to bifurcate the load.

Action plan: As reported by Assistant Executive Engineer (Ele) Rural Sub
Division Hospete the new link line was commission on 12.01.2022 and the
interruption is minimized.

Meeting concluded with vote of thanks to the all officers and HT/EHT consumers
who has attended the meeting

Yours faithfully,


Superintending Engineer (Ele),
O&M Circle, GESCOM,
Ballari

Copy with compliments to ;

1. The Chief Engineer(Ele), Operation, Corporate Office GESCOM Kalaburagi for
kind information.
2. The Chief Engineer(Ele), O & M Zone GESCOM Ballari for kind information

Copy for information to;

- 3.SPS to MD to place the subject before Hon'ble Managing Director GESCOM.
- 4.SPS to DT to place the subject before Hon'ble Director Of Technical GESCOM.
- 5.All Executive Engineer (Ele), O&M Urban/Rural /Hospet/H.B.Halli .
- 6.Executive Engineer (Ele), C&M division GESCOM Ballari.
- 7.All Assistant Executive Engineer (Ele), O & M Urban/Rural Sub-Division, GESCOM
Hospet/H.B.Halli/ Hospet USD-1 & 2.
- 8.copy to SAR/OC/MF.